

Certificate of constancy of performance,

0832-CPR-F0167

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

ENDA2000 Nexus Pulse 110 Conventional Sounder with Red Light LED Visual Alarm Device

(For full product details and conditions of use refer to appendix)

Produced by or for

Texecom Ltd

**Bradwood Court
St Crispin Way
Haslingden
Lancashire
BB4 4PW**

and produced in the manufacturing plant(s)

Texecom Ltd

**Bradwood Court
St Crispin Way
Haslingden
Lancashire
BB4 4PW**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-23:2010 – Visual alarm devices
EN 54-3: 2001 + A1: 2002 + A2: 2006 - Sounders**

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 01 August 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Steve Patrick, Business Group Manager
On behalf of BRE Global Limited
Date of issue: 01 August 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0167

Note:

VAD meets the requirements of EN 54-23:2010 as follows:

- Category W-2.4-7.5
- Flash rate 0.5Hz & 1Hz
- Synchronisation

Sounder Tones:

1. 970Hz continuous
2. 800/970Hz alternating 2Hz
3. 800-970Hz sweep@1Hz
6. 554Hz, 0.1s / 440Hz, 0.4s
7. 500-1200Hz in 3.5s, 0.5s off
13. 1200-500Hz sweep@1Hz

Base:

18-186312 Nexus 110 Mounting Base



Steve Patrick, Business Group Manager
On behalf of BRE Global Limited
Date of issue: 01 August 2014
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.